

Triggered Source Monitoring and Reporting Violation: Groundwater Rule

The City of Denver City water system, PWS #2510001, failed to collect the required number of triggered source bacteriological samples for fecal indicator monitoring of the ground water system during June, 2021. This monitoring is required by the Texas Commission on Environmental Quality's "Drinking Water Standards" and the federal "Safe Drinking Water Act," Public Law 95-523.

Triggered source samples are used to monitor water quality and indicate if the water is free of fecal indicator bacteria. Following a positive routine total coliform result in our distribution system, our water system is required to submit one triggered source sample for every active ground water well. Failure to collect all required triggered source samples is a violation of the monitoring requirements and we are required to notify you of this violation.

What should I do?

There is nothing you need to do at this time. You may continue to drink the water. If a situation arises where the water is no longer safe to drink, you will be notified within 24 hours.

What is being done?

Required water sampling has been performed along with any necessary treatment. For more information, or if you have questions regarding this violation, you may contact Stan David at 806-592-5426 or PO Box 1539, Denver City, TX 79323.

Posted/Delivered on January 20, 2022