



501 S. Main St. - P.O. Box 228. Rhome, Texas 76078

Telephone: 817-636-2462

Fax: 817-636-2465 - www.cityofrhome.com

City of Rhome

2023 Consumer Confidence Report for Public Water System #TX2490007



This is your water quality report for January 1 to December 31, 2023

CITY OF RHOME provides surface water and ground water from Paluxy Aquifer and Bridgeport Lake located in Wise County.

For more information regarding this report contact:

Name: Jesus Dominguez

Phone 940-210-6501

Este reporte incluye información importante sobre el agua para tomar.
Para asistencia en español, favor de llamar al telefono 940-210-6501.



501 S. Main St. - P.O. Box 228. Rhome, Texas 76078

Telephone: 817-636-2462

Fax: 817-636-2465 - www.cityofrhome.com

Definitions and Abbreviations

Definitions and Abbreviations	The following tables contain scientific terms and measures, some of which may require explanation.
Action Level:	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Avg:	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
Level 1 Assessment:	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment:	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level or MCL:	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal or MCLG:	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum residual disinfectant level or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum residual disinfectant level goal or MRDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.



501 S. Main St. - P.O. Box 228. Rhome, Texas 76078

Telephone: 817-636-2462

Fax: 817-636-2465 - www.cityofrhome.com

MFL	million fibers per liter (a measure of asbestos)
mrem:	millirems per year (a measure of radiation absorbed by the body)
na:	not applicable.
NTU	nephelometric turbidity units (a measure of turbidity)
pCi/L	picocuries per liter (a measure of radioactivity)



501 S. Main St. - P.O. Box 228. Rhome, Texas 76078

Telephone: 817-636-2462

Fax: 817-636-2465 - www.cityofrhome.com

Definitions and Abbreviations

ppb:	micrograms per liter or parts per billion
ppm:	milligrams per liter or parts per million
ppq	parts per quadrillion, or picograms per liter (pg/L)
ppt	parts per trillion, or nanograms per liter (ng/L)
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.

Information about your Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.



501 S. Main St. - P.O. Box 228. Rhome, Texas 76078

Telephone: 817-636-2462

Fax: 817-636-2465 - www.cityofrhome.com

- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Information about Source Water

CITY OF RHOME Produces ground water from the Paluxy Aquifer and purchases water from WALNUT CREEK SUD. WALNUT CREEK SUD provides purchase surface water from Bridgeport Lake located in Wise County.



501 S. Main St. - P.O. Box 228. Rhome, Texas 76078

Telephone: 817-636-2462

Fax: 817-636-2465 - www.cityofrhome.com

Source water name		Type of water	Report Status	Location
3-400 Morris	West Morris/School Rd	GW	A	Longitude: -97.414927 Latitude: 32.813497
4-300 Randal	Randal St./Logan St.	GW	A	Longitude: -97.469228 Latitude: 32.050966
5-500 Pecan	St. Pecan Ct./Hickory	GW	A	Longitude: -97.469392 Latitude: 33.058258
Surface Water from Walnut Creek	CC From TX1840008	SW	A	Longitude: -97.533576 Latitude: 33.051601

TCEQ completed an assessment of your source water, and results indicate that some of our sources are susceptible to certain contaminants. The sampling requirements for your water system is based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system contact Jesus Dominguez at 940-210-6501.

CITY OF Rhome: 2023 Water Loss Audit

The City of Rhome's Conservation Plan addresses several measures in reducing water loss and improving the efficiency in the use of water. In the water loss audit submitted to the Texas Water Development Board for the time period of January through December 2023, the system lost an estimated 17% of water from the 102,873,310 gallons of water produced/purchased. Leaks, line breaks, un-metered fire protection, hydrant flushing for health and safety purposes, unauthorized consumption, data discrepancies, and other factors all contribute to water loss. The city will continue to audit its water supply.



501 S. Main St. - P.O. Box 228. Rhode, Texas 76078

Telephone: 817-636-2462

Fax: 817-636-2465 - www.cityofrhode.com

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2023	1.3	1.3	0.102	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.

2023 Water Quality Test Results

Disinfection By-Products	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)	2023	20	12.7 - 19.4	No goal for the total	60	ppb	N	By-product of drinking water disinfection.

*The value in the Highest Level or Average Detected column is the highest average of all HAA5 sample results collected at a location over a year

Total Trihalomethanes (TTHM)	2023	52	41.3 - 59.1	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
------------------------------	------	----	-------------	-----------------------	----	-----	---	--

*The value in the Highest Level or Average Detected column is the highest average of all TTHM sample results collected at a location over a year



501 S. Main St. - P.O. Box 228. Rhome, Texas 76078

Telephone: 817-636-2462

Fax: 817-636-2465 - www.cityofrhome.com

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	08/03/2022	0.041	0.041 - 0.041	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Chromium	08/03/2022	4.6	4.6 - 4.6	100	100	ppb	N	Discharge from steel and pulp mills; Erosion of natural deposits.
Cyanide	2023	96.9	51.6 - 96.9	200	200	ppb	N	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories.
Fluoride	08/05/2021	0.0916	0.0891 - 0.0916	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2023	0.113	0.0118 - 0.113	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
--------------------------	-----------------	------------------------	-----------------------------	------	-----	-------	-----------	--------------------------------



501 S. Main St. - P.O. Box 228. Rhome, Texas 76078

Telephone: 817-636-2462

Fax: 817-636-2465 - www.cityofrhome.com

Combined Radium 226/228	11/07/2018	1.5	0 - 1.5	0	5	pCi/L	N	Erosion of natural deposits.
-------------------------	------------	-----	---------	---	---	-------	---	------------------------------

Disinfectant Residual

Disinfectant Residual	Year	Average Level	Range of Levels Detected	MRDL	MRDLG	Unit of Measure	Violation (Y/N)	Source in Drinking Water
Chloramines	2023	1.33	0.5-2.74	4	4	Mg/L	ppm	Water additive used to control microbes.

SW From Walnut Creek SUD Form TX1840008

The following information is provided by Walnut Creek SUD since the City of Rhome purchases treated water from Walnut Creek SUD
2023 Water Quality Test Results

Coliform Bacteria

Maximum Contaminant Level Goal	Total Coliform Maximum Contaminant Level	Highest No. of Positive	Fecal Coliform or E. Coli Maximum Contaminant Level	Total No. of Positive E. Coli or Fecal Coliform Samples	Violation	Likely Source of Contamination
--------------------------------	--	-------------------------	---	---	-----------	--------------------------------



501 S. Main St. - P.O. Box 228. Rhome, Texas 76078

Telephone: 817-636-2462

Fax: 817-636-2465 - www.cityofrhome.com

0	1 positive monthly sample.	1		0	N	Naturally present in the environment.
---	----------------------------	---	--	---	---	---------------------------------------

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	09/14/2021	1.3	1.3	0.083	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	09/14/2021	0	15	1	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

2023 Water Quality Test Results



501 S. Main St. - P.O. Box 228. Rhome, Texas 76078

Telephone: 817-636-2462

Fax: 817-636-2465 - www.cityofrhome.com

Disinfection By-Products	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorite	2023	0.75	0.246 - 0.75	0.8	1	ppm	N	By-product of drinking water disinfection.
Haloacetic Acids (HAA5)	2023	18	10.2 - 20.1	No goal for the total	60	ppb	N	By-product of drinking water disinfection.

*The value in the Highest Level or Average Detected column is the highest average of all HAA5 sample results collected at a location over a year

Total Trihalomethanes (TTHM)	2023	51	30.2 - 68.7	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
------------------------------	------	----	-------------	-----------------------	----	-----	---	--

*The value in the Highest Level or Average Detected column is the highest average of all TTHM sample results collected at a location over a year

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	2023	0.073	0.073 - 0.073	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.



501 S. Main St. - P.O. Box 228. Rhyme, Texas 76078

Telephone: 817-636-2462

Fax: 817-636-2465 - www.cityofrhyme.com

Cyanide	2023	30.5	30.5 - 30.5	200	200	ppb	N	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories.
Fluoride	2023	0.2	0.232 - 0.232	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2023	0.0553	0.0553 - 0.0553	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Beta/photon emitters	2023	6.3	6.3 - 6.3	0	50	pCi/L*	N	Decay of natural and man-made deposits.

*EPA considers 50 pCi/L to be the level of concern for beta particles.



501 S. Main St. - P.O. Box 228. Rhome, Texas 76078

Telephone: 817-636-2462

Fax: 817-636-2465 - www.cityofrhome.com

Turbidity

	Level Detected	Limit	Violation	Likely Source of Contamination
Highest single	0.12 NTU	1 NTU	N	Soil runoff.
Lowest monthly %	100%	0.3 NTU	N	Soil runoff.

Information Statement: Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of our filtration system and disinfectants.

Total Organic Carbon

The percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirements set, unless a TOC violation is noted in the violations section.